



**TOWN OF BRIGHTON**  
**Office of the Fire Marshal**  
 2300 Elmwood Avenue  
 Rochester, New York 14618  
 (585) 784-5220 Office  
 (585) 784-5207 Fax

**Fire Alarm Affidavit for Alterations or Tenant Improvements (1-20 Fire Alarm Devices - Without Stamped Plans)**

*In accordance with the Code of the Town of Brighton and the New York State Fire Prevention and Building Code, an Fire Alarm Affidavit for Alteration or Tenant Improvement operational permit is required to install, alter or modify an existing automatic fire alarm system.*

Make Checks Payable – Town of Brighton

Fire Alarm Affidavit for Alterations or Tenant Improvements Permit - \$50.00

<b>Applicant &amp; Property Information</b>	Business Name									
	Address				Suite		City		State	Zip Code
	Telephone		Work Telephone				Email Address			
	<b>Property Owner or Mailing Address if different from above</b>									
	Name or DBA									
	Address				Suite		City		State	Zip Code
Telephone		Work Telephone								
<b>Installation Company / Agent to Owner</b>	Name									
	Contact Name									
	Address						City		State	Zip Code
	Telephone			Mobile Telephone			Work Telephone			
<b>System Information</b>	<b>SCOPE OF WORK</b>					<b>SYSTEM INFORMATION</b>				
	NEW	REMODEL	ALTERATION	AUTOMATIC	MANUAL	BOTH	REQUIRED	NON-REQUIRED		
	<b>INDICATE NUMBER OF PROPOSED DEVICES TO BE WORKED ON</b>									
	<b>SMOKE DETECTORS</b>		<b>HEAT DETECTORS</b>		<b>MANUAL PULL STATIONS</b>		<b>AUDIO / VISUAL DEVICES</b>		<b>VISUAL ONLY DEVICES</b>	
	ADDED	RELOCATED	ADDED	RELOCATED	ADDED	RELOCATED	ADDED	RELOCATED	ADDED	RELOCATED
	<b>DESCRIPTION OF WORK TO BE DONE</b>									

# Fire Alarm Affidavit for Alterations or Tenant Improvements

## Scope of Application

---

For 1 to 20 of any combination of the following devices: spot smoke or heat detectors, horn/strobes, strobes, horns, mini-horns, manual pull stations **OR** Supervision of a single duct smoke detector.

**The following are not eligible devices for the affidavit process:** control panels, power supplies, dialers, central station supervisory links, beam detectors, Vesda systems, and "protecto-wire" like detection systems, detection required for initiating fire protection systems such as pre-action or clean agent systems or elevator recall.

## Constraints

---

This affidavit covers one inspection. Additional inspections shall incur additional fees.

Total candela added **shall be equal to or less than 120db**

Detectors shall not exceed 30ft x 30ft spacing or be more than 21 ft from any point they are covering. Ceiling height shall not exceed 12 ft.

Extension of notification circuits (horn and strobe circuits) shall be accomplished using a minimum of 14 GA wire.

## Requirements

---

All work complies with at least the current state-adopted NFPA-72 and the authority having jurisdiction.

All notification appliances are located in accordance with at least the current state-adopted NFPA-72.

Smoke/Heat detector spacing complies with at least current state-adopted NFPA-72 and the authority having jurisdiction.

Voltage drop is adequate to operate all appliances.

Battery supplies are capable of supporting the system modifications.

Exposed wiring will not be covered until inspected.

## Plans shall include

---

Written scope of work.

A site drawing indicating the general location of the work area.

A graphical scale floor plan drawing indicating the new locations of the devices and any end of line resistors.

The listing sheets for the various devices.

Symbol legend for applicable devices installed.

Compatibility information of appliances and new devices and existing devices are in accordance with the FACP manufacturer's specifications.

End of line voltage readings for existing notification circuits effected.

Current readings for each circuit on respective power supplies.

Current limits for power supplies (per circuit total).

Wiring class on new circuits (A or B).

## Final Acceptance Testing

---

The contractor shall be present, shall have pre-tested the system, and have all of the materials and equipment on hand necessary to execute the final acceptance inspection procedure.

Contractor shall present the Fire Marshal / Fire Inspector with the following paperwork at the job site:

A statement of compliance, with the minimum information as specified in Fire Code of New York State - Section 901.2.1,.

NFPA 72 Record of completion to be presented to *Fire Marshal / Fire Inspector* at final inspection.

Work that exceeds the scope of the affidavit will require a new permit of the appropriate scope.

Final approval shall be subject to onsite tests and inspections.

I understand a sketch is required to be attached to this document showing the area of work within the building's structure, and a copy of this document shall be available for all inspections.

I, \_\_\_\_\_, certify that the following is true and reasonably defines the scope of work for this project:

Applicant Signature			Applicant Name (Print)			Application Date
<b>Permit Number</b>	<b>Issue Date</b>	<b>New Expiration Date</b>	<b>Fee Paid</b>	<b>Check #</b>	<b>Receipt Number</b>	<b>Evacuation Plan Received</b>