



Fire Alarm Affidavit for Alterations or Tenant Improvements

(1-20 Fire Alarm Devices - Without Stamped Plans)

In accordance with the Code of the Town of Brighton and the New York State Fire Prevention and Building Code, a Fire Alarm Affidavit for Alteration or Tenant Improvement operational permit is required to install, alter or modify an existing automatic fire alarm system.

Property Information	Make Checks Payable – Town of Brighton				Alterations or Tenant Improvements Permit Application - \$50.00										
	Business Name														
	Address				Suite		City		State	Zip Code					
Installation Company / Agent to Owner	Telephone		Work Telephone				Email Address								
	Company Name														
	Contact Name														
	Address						City		State	Zip Code					
	Telephone			Mobile Telephone			Work Telephone								
Email Address															
System Information	SCOPE OF WORK					SYSTEM INFORMATION									
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
	NEW		REMODEL		ALTERATION		AUTOMATIC		MANUAL		BOTH		REQUIRED		NON-REQUIRED
	INDICATE NUMBER OF PROPOSED DEVICES TO BE WORKED ON														
	SMOKE DETECTORS			HEAT DETECTORS			MANUAL PULL STATIONS			AUDIO / VISUAL DEVICES			VISUAL ONLY DEVICES		
	ADDED	RELOCATED		ADDED	RELOCATED		ADDED	RELOCATED		ADDED	RELOCATED		ADDED	RELOCATED	
DESCRIPTION OF WORK TO BE DONE															

I understand a sketch is required to be attached to this document showing the area of work within the building's structure, and a copy of this document shall be available for all inspections.

By signing below, I hereby apply for a Fire Protection System Installation permit and certify that I have read and understand the information package for the installation requirements pertinent to this permit and agree to abide by them. This application for a Fire Code Operational Permit will be in accordance with all ordinances of the Town of Brighton and the Fire and Building Code of New York State and that any plans or specifications submitted with this application are the plans or specifications relating to this permit.

I further understand this is not a permit but only an application for permit and construction work is not to start without a permit; that the work will be in accordance with the approved plans.

Applicant Signature			Print Name (Applicant)			Date		
Permit Number	Issue Date	Expiration Date	Fee Paid	Check #	Receipt Number	Plan Review Fee		

Fire Alarm Affidavit for Alterations or Tenant Improvements

Scope of Application

For 1 to 20 of any combination of the following devices: spot smoke or heat detectors, horn/strobes, strobes, horns, mini-horns, manual pull stations **OR** Supervision of a single duct smoke detector.

The following are not eligible devices for the affidavit process: control panels, power supplies, dialers, central station supervisory links, beam detectors, Vesda systems, and "protecto-wire" like detection systems, detection required for initiating fire protection systems such as pre-action or clean agent systems or elevator recall.

Constraints

This affidavit covers one inspection. Additional inspections shall incur additional fees.

Total candela added **shall be equal to or less than 120db**

Detectors shall not exceed 30 ft x 30 ft spacing or be more than 21 ft from any point they are covering. Ceiling height shall not exceed 12 ft.

Extension of notification circuits (horn and strobe circuits) shall be accomplished using a minimum of 14 GA wire.

Requirements

All work complies with at least the current state-adopted NFPA-72 and the authority having jurisdiction.

All notification appliances are located in accordance with at least the current state-adopted NFPA-72.

Smoke/Heat detector spacing complies with at least current state-adopted NFPA-72 and the authority having jurisdiction.

Voltage drop is adequate to operate all appliances.

Battery supplies are capable of supporting the system modifications.

Exposed wiring will not be covered until inspected.

Plans shall include

Written scope of work.

A site drawing indicating the general location of the work area.

A graphical scale floor plan drawing indicating the new locations of the devices and any end of line resistors.

The listing sheets for the various devices.

Symbol legend for applicable devices installed.

Compatibility information of appliances and new devices and existing devices are in accordance with the FACP manufacturer's specifications.

Wiring class on new circuits (A or B).

Final Acceptance Testing

The contractor shall be present, shall have pre-tested the system, and have all of the materials and equipment on hand necessary to execute the final acceptance inspection procedure.

Contractor shall present the Fire Marshal / Fire Inspector with the following paperwork at the job site:

- A statement of compliance, with the minimum information as specified in Fire Code of New York State - Section 901.2.1.
- NFPA 72 Record of completion to be presented to Fire Marshal / Fire Inspector at final inspection.
- Work that exceeds the scope of the affidavit will require a new permit of the appropriate scope.
- Final approval shall be subject to onsite tests and inspections.